

To confirm the validity of the gas operative please contact the gas registration body.

Serial No.
11122

MOBILE CATERING VEHICLE / TRAILER SAFETY CHECK

Equipments

NEXT SAFETY
CHECK DUE WITHIN
6 MONTHS



This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Registered Business Details REGISTRATION NO **199631**
 Gas operative **G. JACKSON** (Print name)
 ID card serial No. **4042310**
 Company **CATERTECH**
 Address **18 Brynards Hill**
WOOTTON BASSETT SWINDON WILTS
 Postcode **SN47ER** Tel No. **01793 848002**

Details of Vehicle Trailer tick appropriate box
 Reg No. or Serial/Chassis No. **P122A**
 LPG cylinder holding satisfactory **Yes**
 Fire extinguisher(s) provided **Yes**
 Fire blanket provided **Yes**
 Current safety certificate displayed **Yes**
 Safe use of LPG information displayed **Yes**

Vehicle/Trailer Owner Details **GREEN PEPPER**
 Name (Mr/Mrs/Miss/Ms) **Red Thomas**
 Address **The Farm 3, HSRIDAN HSE**
Barry
 Postcode **BA1222** Tel No. **07853771297**
 No. of appliances tested **20**

APPLIANCE DETAILS						
Appliance type	Make	Model	Serial No.	Flue type OF/RS/FL	Is appliance secure Yes/No	Is appliance isolation valve fitted Yes/No
1 Pizza Oven	SEAL GAS	EG9	01-06	FL	Yes	Yes
2 Granite Burners	POWELL	ATP	C1-C14	FL	Yes	Yes
3						
4						

INSPECTION DETAILS								
Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1 16kW	Yes	Yes	Yes	NA	NA	NA	Yes	Yes
2 7.5kW	Yes	Yes	Yes	NA	NA	NA	Yes	Yes
3								
4								

If Warning/Advice Notice
Issued insert serial No.

Cylinder/final connection hoses to installation satisfactory Yes/No
 Gas installation pipework (visual inspection) satisfactory Yes/No
 Gas tightness/soundness test satisfactory Yes/No/NA
 ECV accessible and operable Yes/No
 LPG regulator operating pressure (mbar)
 LPG regulator lock-up pressure (mbar)

Safety check issued by: Signed **G. JACKSON**
 Print name: **G. JACKSON**
 Received by: **Red Thomas**
 Date appliance(s)/flue(s) checked: **04 APR 2017**

Catertech
 Multi-Skilled Professional Catering Engineers
 Service, Repair, Sales & Installation
 Proprietor: **George Jackson**
 18 Brynards Hill
 Wootton Bassett
 Swindon
 Wiltshire SN4 7ER
 www.catertech.co.uk
 email: george@catertech.co.uk
 Tel/Fax: +44 01793 848002
 Mobile: 07976 243815

199631
 JW
 Copy - Registered Business
 Refer to separate Warning/Advice Notice