

## Inspection Certificate

t. 01992 893 498

e. servicedesk@morganfire.co.uk



<b>Customer</b>	Flat 3	<b>Call Type</b>	Preventative Maintenance
<b>Customer No.</b>	GREENPEP	<b>System Type</b>	Portable Extinguishers
<b>Customer Reference</b>		<b>Schedule Type</b>	Annual Inspection
		<b>Police Status</b>	U
<b>Site Name</b>	Green Pepper Red Tomato Management Company	<b>Call Number</b>	2773228
<b>Site ID</b>	MFP40032	<b>Call Reason</b>	Preventative Maintenance
<b>Address</b>	Westhay Road Westhay Glastonbury	<b>Contact</b>	
		<b>Property Ref</b>	
<b>Postcode</b>	BA6 9TL	<b>Telephone No.</b>	07821281528

### Remarks

Preventative Maintenance : Annual Inspection

Notes :

### Actions

Annual inspection conducted. New equipment supplied as requested. Extinguishers serviced in van..

### Parts Used

Quantity	Description
1	Visit To Site Fee
5	Tamper Tag
5	Hose / Horn Washer
4	Gauge Test
1	Foam 6Ltr Fire Extinguisher
3	D6Kg Dry Powder Fire Extinguisher
3	CO2 2Kg Fire Extinguisher
1	Condemned And Removed Fire Extinguisher (Chargeable)
3	Fire Blanket 1.2 x 1.2 M
1	Fire Blanket 1.2 x 1.8 M
7	New Extinguisher / Commission To Bs5306

### Checklist

Item	Checked	Remarks
Extinguishers inspected and serviced in accordance with P BS5306 Part 3		Annual inspection conducted
3L Water	0	
6L Water	0	
9L Water	0	
3L Water Mist	0	
6L Water Mist	0	
9L Water Mist	0	
2L AFFF	0	
3L AFFF	0	

6L AFFF	P	3 x basic service 1 x new supplied commissioned
9L AFFF	0	
2kg CO2	P	1 x basic service 3 x new supplied commissioned
5kg CO2	0	
1kg Dry Powder	0	
2kg Dry Powder	0	
3kg Dry Powder	0	
4kg Dry Powder	0	
6kg Dry Powder	P	1 x basic service 3 x new supplied commissioned
9kg Dry Powder	P	1 x condemned and removed as due for the extended service. Alternative replacements supplied
2L Wet Chemical	0	
3L Wet Chemical	0	
6L Wet Chemical	0	
Tamper Tags Changed	P	x 5
O Rings Changed	P	x 5
Gauge Test Carried Out	P	x 4
Fire Blanket	P	4 x new supplied commissioned
Hose Reel	0	
Other sizes/types Not Listed Above	0	
All product has been serviced and passed and no failures are present	0	
Equipment listing has changed. Office to amend.	0	
Equipment Quotation Required	0	
Service Quotation Required	0	
Waste removed from site ?	0	
Is there appropriate Company signage / labels affixed to the relevant equipment? (Y/N)	P	.

### Risk Assessment

Item	Checked	Remarks
Working at heights (L,M,H)	P	LOW
Fall of tools and materials (L,M,H)	P	LOW
Slips, trips and falls (L,M,H)	P	LOW
Use of power & hand tools (L,M,H)	P	LOW
Work in confined spaces (L,M,H)	P	LOW
Working with asbestos materials (L,M,H) - Is asbestos register on site? (Y/N)	P	LOW/ unknown
Working alone (L,M,H)	P	LOW
Working in occupied premises (L,M,H)	P	LOW
Fire on site (L,M,H)	P	LOW
Manual handling (L,M,H)	P	LOW
Vibration due to drilling (L,M,H)	P	LOW
PPE equipment required (L,M,H)	P	LOW
Other risks - please specify	P	NONE
Works to proceed ?	P	YES

---

**Fault Code****Fault Group**

---

**Declaration**

The Company certify that, unless otherwise stated, the inspection has been carried out in accordance with BS:5306-3: 2017 and part 8 2012

**Arrived On Site** 11:07:00 21/03/2022**Time Left Site** 11:45:00 21/03/2022**Engineers Declaration**

I confirm that the work undertaken is, to the best of my knowledge, in accordance with the dynamic risk assessment undertaken and to the recommendations of British Standards and that all areas of non conformity have been brought to the attention of the Customer.

**Engineer Name** Andy Draper**Engineer Signature****Customer Satisfaction**

I confirm that there has been no 3rd party interference with System since the last attendance of the Company. The work undertaken has been completed to my satisfaction and the Engineer has brought to my attention any/all areas of non conformity. I agree that the work should be charged at the standard rates of the Company.

**Customer Name** Signed For Ed Wooldridge**Customer Signature**

All work undertaken is subject to the Terms & Conditions of the Company