

Portable Appliance Testing (PAT)

Certificate Reference – 2374 KS

DETAILS OF CLIENT

Client/
Address: Westhay Business Park, Main Road, Westhay, Meare, BA6 9TL

TESTING DETAILS

Test Equipment used	Seaward PrimeTest 50	Serial Number	40DD-0037
Engineer	Emily May	Date	19/04/22
		Re-test	19/04/23

APPLIANCE ID	DESCRIPTION	LOCATION	RESULT Visual/Earth Continuity/Insulation Resistance,Polarity,Function
01	Temp supply power bank		PASS ✓
02	Temp supply power bank		PASS ✓
03	Water heater/cooler		PASS ✓
04	Water heater/cooler		PASS ✓
05	Water heater/cooler		PASS ✓
06	Water heater/cooler		PASS ✓
07	Blender		PASS ✓
08	Blender		PASS ✓
09	Blender		PASS ✓
10	Extension plug		PASS ✓
11	3m 3 way extension lead		PASS ✓
12	Kettle		PASS ✓
13	12m blue extension lead		FAIL X
14	Flood light		PASS ✓
15	SMJ 4 way extension lead		PASS ✓

16	Floodlight		PASS ✓
17	Floodlight		PASS ✓
18	Floodlight		PASS ✓
19	Floodlight		PASS ✓
20	Floodlight		PASS ✓
21	Splitter extension plug		PASS ✓
22	Cash register		PASS ✓
23	Extension lead		PASS ✓
24	Extension lead		PASS ✓
25	Extension lead		PASS ✓
26	Extension lead		PASS ✓
27	Extension lead		PASS ✓
28	Extension lead		PASS ✓
29	Extension lead		PASS ✓
30	Extension lead		PASS ✓
31	Extension lead		PASS ✓
32	15m 4 way extension lead		PASS ✓
33	15m 4 way extension lead		PASS ✓
34	15m 4 way extension lead		PASS ✓
35	8m 4 way extension lead		PASS ✓
36	10m 4 way extension lead		PASS ✓
37	6 way extension lead		FAIL X
38	2m 4 way extension lead		PASS ✓
39	2 way 2m extension lead		PASS ✓
40	2 way extension lead		PASS ✓
41	Yellow extension lead		PASS ✓
42	Black extension lead		PASS ✓
43	Black extension lead		PASS ✓
44	White extension lead		PASS ✓
45	Blue extension lead		PASS ✓
46	Blue extension lead		PASS ✓
47	Blue extension lead		FAIL X
48	Extension plug		PASS ✓
49	Splitter plug		PASS ✓
50	Splitter plug		PASS ✓
51	Splitter plug		PASS ✓
52	Splitter plug		PASS ✓
53	Splitter plug		PASS ✓
54	Floodlight		PASS ✓
55	Floodlight		PASS ✓
56	Floodlight		PASS ✓
57	Floodlight		PASS ✓
58	Floodlight		PASS ✓
59	Floodlight		PASS ✓
60	Floodlight		PASS ✓
61	Floodlight		PASS ✓
62	Floodlight		PASS ✓

Portable Appliance Testing (PAT)

Appliances that have been noted as visually tested only

Where unplugging of an appliance is not feasible due to the high inconvenience and disruption of the particular equipment, appliances have been visually inspected and been issued a **PASS ✓** sticker but have not been tested to check earth continuity and insulation resistance of conductors.

Failed Appliances

Failed Appliances should not be used at any time, they have been failed for a reason and identified as unsafe to use.

Surge protected extension leads

Surge protected extension leads have only been noted because when testing conductors on test 2 (insulation resistance) the tester identifies it as failed but, however it just because the extension lead is surge protected and gives a false reading.