

LAB012612

MOBILE CATERING VEHICLE/TRAILER SAFETY RECORD

This Safety Record can be used to document the outcomes of the checks and tests required by The Gas Safety (Installation and Use) Regulations.
Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.

Gas Safe is a registered trade mark of HSE, and is used under licence.

Details of Registered Business

Gas Safe Register No 199631
Registered Engineer's Name G. JACKSON
Gas Safe Register Licence Number 5278317
Business CATERTECH
Address 18 BRYNARDS HILL
WOOTTON BASSETT, SWINDON, WILTS
Postcode SN4 7ER
Contact No 01793 848002

Vehicle/Trailer Details

Vehicle ☐ or Trailer ☐ (Please check relevant box ☒)
Chassis/Serial Number _____
or
Reg Number _____
Trading Title GREEN PEPPER ROAD TOMATO MGMT

Vehicle/Trailer Owner Details

Name (Mr/Mrs/Miss/Ms) M NWCARO
Address FIRST FLOOR
HEATHLAND, BRIDGE ROAD
BRISTOL
Postcode BS8 3PA
Contact No 07853771397

Record Issued by:

Signature: G. JACKSONPrint Name: G. JACKSON

Received By

Signature: [Signature]Date: 15 MARCH 2022

	Appliance Type	Manufacturer	Model	Type of flue/ chimney	Operating pressure	Operation of safety device(s) <input checked="" type="checkbox"/>	Ventilation satisfactory <input checked="" type="checkbox"/>
1	PIZZA OVEN	CASIRO DEMUS	9GPL(01-03)	N/A	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
2	STATIONARY BURNER	QTY 19 (H23-49)	ATP	N/A	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
3	PANINIA BURNER	VAELLO X2 CAMPUS(01-02)	XX 600	N/A	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
4	PIZZA OVEN	HOS-EL X2 (H01-02)	G9	N/A	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>

	Visual condition off flue/ chimney and termination <input checked="" type="checkbox"/>	Flue/Chimney operation checks <input checked="" type="checkbox"/>	Appliance isolation valve fitted <input checked="" type="checkbox"/>	Is appliance secure <input checked="" type="checkbox"/>	Serviced <input checked="" type="checkbox"/>	Safe to use <input checked="" type="checkbox"/>
1	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
2	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
3	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
4	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>

Gas installation details

Is the LPG cylinder housing satisfactory?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/>
Is the ECV accessible, labelled and operable?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Is visible gas pipework including gas hoses satisfactory?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Is the gas installation gas tight?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
LPG Regulator operating pressure	37 mbar
LPG Regulator lock-up pressure	42 mbar

General safety

Is there a fire extinguisher(s) provided?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Is a fire blanket provided?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Is the current safety record displayed?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Is 'Safe use of LPG information' displayed?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>

Any Defects Identified

① PIZZA OVEN GAS HOSES KINKED
② PIZZA OVEN BURNERS BLOCKED

GIUSP classification
e.g. AR, ID

N/A

Warning/Advice Record
insert form serial No.

N/A

Remedial Action Taken

The above defects rectified & appliances
functionally tested SANS

ATTENTION

Next safety
check due by:

14
March
2023